APPENDIX E: WOOD-WASTE-FIRED BOILER EMISSIONS TEST SUMMARIES

Emission Test Report

for

The University of Idaho

Wood Fired Boiler

of

Particulate Matter

Carbon Monoxide

&

Opacity

TE&E Project #9639

March 23, 1998

Prepared for: The University of Idaho Facilities Management Moscow, ID 83844-1231 (208) 885-6246

Prepared by: Travis Energy & Environment, Inc. 9321 N. Government Way, Suite H Hayden Lake, ID 83835-8263 (208) 772-9149

TABLE OF CONTENTS

Appendices	
List of Figures	ii
List of Tables	ii
Certification Statement	iii
1. INTRODUCTION	1
1.1 Summary of Test Program	
1.2 Key Personnel	1
2. PLANT AND SAMPLING LOCATION DESCRIPTION	1
2.1 Process Description and Operation.	1
2.2 Control Equipment Description	3
2.3 Flue Gas Sampling Locations	3
2.4 Process Sampling Locations	
3. DISCUSSION OF TEST RESULTS	4
3.1 Specific Objectives and Test Matrix	4
3.2 Field Changes	
3.3 Presentation of Results	
3.3.1 Particulate Results	5
3.3.2 Analyzer Tests	
3.3.3 Opacity Results	
4. SAMPLING AND ANALYTICAL PROCEDURES	5
4.1 Test Methods	5
4.2 Process Sample Tests	
5. QA/QC ACTIVITIES	8
5.1 Particulate Testing	8
5.2 Method 5 Train Metering System Audit	8
5.3 Method 5 Blank Audits	
5.4 Instrument Analysis	8

APPENDICES

Plant Proce	ess Data	Appendix A
Method 10	Data Sheets	Appendix B
Methods 5	Data	Appendix C
Opacity Da	ta	Appendix D
	LIST OF FIGURES	1 at 1
Figure 1	Boiler Facility Process Diagram	2
	LIST OF TABLES	
Table 2-1	Fuel Properties	3
Table 2-2	Process Flow Rates	3
Table 3-1	Sampling Matrix	4
Table 3-2	Particulate Emissions Results	6
Table 3-3	Methods 10 Summary Table	7
	LIST OF GRAPHS	
Graph 3.3-1	CO Concentration, Test 1	9
Graph 3.3-2	CO Concentration, Test 2	10
Graph 3.3-3	CO Concentration, Test 3	11

1. INTRODUCTION

1.1 Summary of Test Program

The University of Idaho (U of I) contracted with Travis Energy & Environment, Inc. (TE&E) to perform emissions testing of the Solid Fuels Inc. furnace at their Moscow power plant. The boiler was fired by hogged fuel and wood chips.

The specific test objectives were to measure particulate matter and carbon monoxide emissions, and opacity from the boiler. Carbon monoxide testing was carried out on February 26, 1998, the opacity determination was done on February 27, 1998, and the particulate testing was done on February 28, 1998.

1.2 Key Personnel

The key personnel who coordinated the test program were:

Project Manager	Brent N. Travis, TE&E	208-772-9149
University Contact	Don Husky, U of I	208-885-7350
Plant Contact	Gerald Hanks, U of I	208-885-6271

2. PLANT AND SMAPLING LOCATION DESCRIPTION

2.1 Process Description and Operation

The Solid Fuels Inc. furnace fires a Nebraska boiler. A block diagram of the facility is shown in Figure 1. The Nebraska boiler's nameplate ring is 60,000 pph of steam. Operating steam flows during testing ranged between 48,000 and 81,000 pph of 127 to 160 psig steam. A steam production factor of 6.90 lbs of steam per bone dry lb of wood was determined as shown in Appendix A. The properties of the wood waste fired are presented in Table 2-1. Methods of analysis and number of samples tested are stated in Appendix A. Table 2-2 shows fuel and steam average flow rates for each test calculated from the steam integrator and the above steam production factor.

Chart trends showing steam flow, steam pressure, % oxygen, % opacity, collector pressure and system temperature profiles are presented in Appendix A.

Table 2-1 Fuel Properties

Property	Average	Maximum	Minimum	Standard Deviation
Moisture, wt%	51.2	57.3	32.8	3.55
Combustibles, wt%, dry basis	98.4	98.9	98.1	0.25
Ash, dry wt%	1.64	1.95	1.12	0.25
Higher Heating Value BTU / dry lb	9498	11074	8644	488

Table 2-2 Process Flow Rates

Test	Fuel BD lbs	Fuel Flow BD lbs/hr	Steam 1,000 lbs	Steam Flow kpph
1	12174	11781	84	81
2	9130	8695	63	60
3	12609	7642	87	53
5	N/A	N/A	N/A	N/A
6	12319	8213	85	57
7	10145	7515	70	52
8	9420	6978	65	48

2.2 Control Equipment Description

Emissions from the boiler are controlled by an internal cyclone. Opacity is recorded by a continuous emissions monitoring system (CEMS). Both the boiler and CEMS were in sound working condition.

2.3 Flue Gas Sampling Locations

The unit has an inner stack diameter of 59". Two sampling ports (90 degree offset) are located greater than eight stack diameters, from the top of the stack which is the nearest downstream flow disturbance. The upstream distance to the nearest flow disturbance is approximately 4.2 stack diameters from the ports. Twenty-four traverse points were sampled for the Solid Fuels Stoker unit particulate test; stack traverse points were located at:

1.24, 3.95, 6.96, 10.44, 14.75, 21.00, 38.00, 44.25, 48.56, 52.04, 55.05, and 57.76 inches along the two diameters tested.

2.4 Process Sampling Locations

Fuel samples were collected from the boiler feed system during testing of U of I personnel. The sample was double sealed in large freezer zip lock bags and tested as outlined in section 4.2.

3. DISCUSSION OF TEST RESULTS

3.1 Specific Objectives and Test Matrix

The test was to obtain and document data for determination of particulate and carbon monoxide emission and opacity for compliance after unit modification. Specific test objectives were as follows:

- Measure particulate matter emissions from the boiler stack by EPA Reference Methods 5 (including EPA Reference Methods 1, 2, 3, and 4).
- Measure Carbon Monoxide emissions from the boiler stack by EPA Reference Method 10 using EPA Reference Method 6C QA/QC protocol.
- Opacity was carried out in accordance with Idaho Division of Environmental Quality's "Evaluation of Visible Emissions Manual".

Table 3-1 presents the actual sampling matrix log.

Table 3-1 Sampling Matrix

Date	Run #	Sample Type	Location	Test Method	Start Time	Sample Time
02/26/98	1	CO	Solid Fuels Unit Stack	M10	15:14	62 min
02/26/98	2	СО	Solid Fuels Unit Stack	M10	17:30	63 min
02/26/98	3	СО	Solid Fuels Unit Stack	M10	19:46	99 min
02/27/98	4	PM	Solid Fuels Unit Stack	M5	14:26	scratched due to equipment
02/27/98	5	Opacity	Solid Fuels Unit Stack	IDEQ	14:00	60 min
02/28/98	6	PM	Solid Fuels Unit Stack	M5	08:37	72 min
02/28/98	7	PM	Solid Fuels Unit Stack	M5	12:00	72 min
02/28/98	8	PM	Solid Fuels Unit Stack	M5	15:39	72 min

3.2 Field Changes

No field changes were made.

3.3 Presentation of Results

3.3.1 Particulate Results

Tables 3-2 summarizes the results of the particulate tests. All results are presented in mass/dscf as well as lb/hr. Field data and detailed analysis tabulated by run are found in Appendix C. Cyclonic flow was checked and was not present in the stack per Method One.

3.3.2 Analyzer Tests

Table 3-3 summarizes the results of the carbon monoxide test. All results are presented in mass/dcsf as well as lb/hr. Carbon monoxide concentration trends expressed as ppm dry volume are presented in Graphs 3.3-1, 3.3-2, and 3.3-3. Tabulated field data by run for each emission point and a copy of the chart record are found in Appendix B.

3.3.2 Opacity Results

A large attached steam plume existed during opacity determination. Observations were made at the point the steam plume dissipated between 100 and 200 feet down wind of the stack. At this observation point zero opacity was present from smoke. The visible emissions observation form presenting field data for the 60 minute test period is located in Appendix D.

4. SAMPLING AND ANALYTICAL PROCEDURES

4.1 Test Methods

EPA Reference Methods 1, 2, 3, 4, and 5, found in Appendix A of 40 CFR 60 were performed with no deviation. The IDEQ method of Opacity determination was carried out for 60 minutes. EPA Reference Method 10 was performed for determination of carbon monoxide with instrument and system bias checks derived from EPA Reference Method 6C.

Table 3-2 Particulate Emission Results

Parameters	Run #6	Run #7	Run #8	Average
Exhaust Temperature, Ts (F)	280	285	285	283
Exhaust Moisture (%)	21.94	21.67	23.42	22.35
Exhaust Velocity, Vs (fpm)	1787	1807	1944	1846
Exhaust Flow Rate, Qs std (dscfm)	17317	17454	18356	17709
Method 5 Particulate				
gr/dscf	0.0636	0.0575	0.0765	0.0659
gr/dscf @ 8% O2	0.0672	0.0566	0.0880	0.0706
lb/hr*	9.4368	8.6000	12.0354	10.0241

Note: * Particulate emissions reported in lb/hr units were calculated as follows: lb/hr = (gr/dscf) X (lb/7000 gr) X (dscf/min) X (60 min/hr)

Table 3-3 Method 10 Summary Table

Concentration data:

Method 10 - CO

Run 1 62 ppm Run 2 55 ppm Run 3 74 ppm Average 64 ppm 4

om 4.62E-06 lb CO/dscf*

* = (MW) * 2.59E-09 lb/dscf/ppm * (PPM)

Mass Emission Data:

Average Test Conditions:

	Run #1	Run #2	Run #3	Avg.
Stack Temp, F	299	274	282	285
Stack Velocity, ft/s	31.5	29.6	32.0	31.0
Stack Moisture (mass/mass)	0.22	0.20	0.24	0.22
Stack Pressure, "Hg absolute Area (ft^2)	27.21	27.21	27.21	27.21 18.99

Avg. CO Emission Rate, lb/hr*

6.3

*Based on: (concentration / dscf) * (1-%moisture/100) * Tstd/Tstack *
Pstack/Pstd * stack gas velocity * stack area

4.626-26/20/2003 x (1-20/20) x 2 655 x 21211; x 314 pec. 3-2000/20 ~ 16:17 36

4.2 Process Sample Tests

The collected fuel sample was tested for moisture, combustibles, ash, and heating value. Results of this analysis are presented in Table 2-1 and Appendix A.

5. QA/QC ACTIVITIES

5.1 Particulate Testing

No QA/QC problems occurred during total particulate testing.

5.2 Method 5 Train Metering System Audit

The metering system was calibrated against a laboratory based calibration dry gas meter using the procedure specified in Method 5. Appendix C shows the dry gas meter calibration performed in the laboratory prior to this project. Appendix C shows the data from the field calibration check of the instrument. Audit results indicated that the dry gas meter was operating correctly during the test.

5.3 Method 5 Analysis Blank Audits


Field blanks of the acetone used for nozzle and probe rinsing were obtained and analyzed similarly to the acetone wash samples, per the required Method 5 procedures.

5.4 Instrument Analysis

Appendix B presents field calibration checks of the instruments. All results fall within allowable standards.

SOURCE EVALUATION REPORT

University of Idaho Moscow, Idaho



Wood Waste-Fired Boiler Exhaust Particulate and Opacity

January 5, 2005

Project No. 2291

Permit No. T1-040207

TABLE OF CONTENTS

Page Number

- 1. CERTIFICATION
- 2. INTRODUCTION
- 3. SUMMARY OF RESULTS
- 4. SOURCE DESCRIPTION AND OPERATION
- 5. SAMPLING AND ANALYTICAL PROCEDURES
- 6. DISCUSSION

APPENDIX Page Number

Nomenclature & Drift Correction Documentation

Particulate

Particulate Emissions Results

Example Calculations

Field Data

Blank Corrections

Laboratory Results, Worksheets, Tare Records, and Chain of Custody

Sample Recovery Field Data and Worksheets

Traverse Point Locations

Visible Emissions

Field Data

Certifications

Gases

Molecular Weight Determination

Analyzer Calibration Data and Bias Checks

Process/Sampling Equipment Flow Diagram

Production/Process Data

Production / Process Data

Fuel Characteristics

Calibration Information

Meter Box and Standard (Critical Orifices)

Pitots

Thermocouples and Indicators

Nozzle Diameters

Barometer

Calibration Gas Certificates

QA/QC Documentation

Procedures

Analyzer Interference Response Data

Correspondence

Source Test Plan and Correspondence

Permit (Selected Pages)

1. CERTIFICATIONS

1.1 Test Team Leader

I hereby certify that the test detailed in this report, to the best of my knowledge, was accomplished in conformance with applicable rules and good practices. The

results submitted herein are accurate Name: Thomas A. Rhodes, E.I.T.	and true to the best of my knowledge.
Signature	Date
1.2 Report Review	
parameter than the second than	is report and find it to be true and accurate les and good practices, to the best of my
Name: David R. Rossman, P.E.	
Signature	Date
Expires 12/31/2006	
1 2 Papart Pavious	

1.3 Report Review

Name: Michael E. Wallace, P.E.

I hereby certify that I have reviewed this report and find it to be true and accurate, and in conformance with applicable rules and good practices, to the best of my knowledge.

Signatura	Data
Signature	Date

2. INTRODUCTION

2.1 Client:

University of Idaho

Facilities Management

2.2 Physical Location:

Power Plant

Moscow, Idaho

2.3 Mailing Address:

1108 W. Sixth Street

Moscow, ID 83844-2030

2.4 Test Log:

Wood-Fired Boiler Exhaust: Particulate and Opacity

Test Date	Run No.	Test Time		
January 5, 2005	1	08:38 - 09:40		
	2	10:09 - 11:12		
"	3	11:34 - 12:36		

Summary: Three valid runs

2.5 Test Purpose: Compliance with Operating Permit No. T1-040207 issued by the Idaho Department of Environmental Quality (DEQ).

2.6 Background Information: None

2.7 Participants:

Horizon Personnel:

Thomas A. Rhodes, E.I.T., Team Leader

Michael E. Wallace, P.E., Calculations and QA/QC

David R. Rossman, P.E., Report Review

Kate Krisor, Technical Writer

Test Arranged by: Mike Lyngholm, University of Idaho Visible Emissions (Opacity) Read By: Mike Lyngholm Observers:

Plant Personnel: Mike Lyngholm

Test Plan Sent to: Clayton Steele, Idaho DEQ

****** HORIZON ENGINEERING ******

3. SUMMARY OF RESULTS - 3.1 Table(s) of Results:

Table 1
Wood-Fired Boiler Test Results

Toot Date: January E 2005	11-14-	D 4	D 0	D 0	***
Test Date: January 5, 2005	Units	Run 1	Run 2	Run 3	Average
Start Time		08:38	10:09	11:34	
End Time		09:40	11:12	12:36	
Sampling Time	min	60	60	60	60
Sampling Results					
Particulate-Filterable (Actual)	gr/dscf	0.039	0.038	0.031	0.036
Conc. @ 8 % O ₂	gr/dscf	0.038	0.036	0.028	0.034
Permit Limit 8% O ₂	gr/dscf				0.08
Particulate Rate	lb/hr	6.7	6.4	4.5	5.9
Permit limit	lb/hr				17.24
Opacity	%	1	1.5	1	1
Sample Volume	dscf	47.8	46.5	42.2	45.5
Sample Weight, Filterable	mg	120	115	84	106
Percent Isokinetic	%	96	97	97	97
O_2	%	7.8	7.1	7.0	7.3
CO ₂	%	12.2	12.9	13.0	12.7
Source Parameters					
Flow Rate (Actual)	acf/min	37,900	37,600	32,000	35,800
Flow Rate (Standard)	dscf/min	20,200	19,600	17,300	19,000
Temperature	°F	315	322	304	314
Moisture	%	16.0	16.7	15.8	16.2
Process/Production Data					
Steam Production	10 ³ lb/hr	56.5	57.3	53.2	55.7
Total Wood Burned During Test	BDT				24
Multiclone Pressure Drop	in. H ₂ O	2.6	2.6	2.2	2.5

3.2 Description of Collected Samples:

Filters: Grey

Impinger Contents: Clear

3.3 Discussion of Errors and Quality Assurance Procedures: This table is taken from a paper entitled "Significance of Errors in Stack Sampling Measurements", by R.T. Shigahara, W.F. Todd and W.S. Smith. It summarizes the maximum error expressed in percent, which may be introduced into the test procedures by equipment or instrument limitations.

Measurement	% Max Error 1.4	
Stack Temperature Ts		
Meter Temperature Tm	1.0	
Stack Gauge Pressure Ps	0.42	
Meter Gauge Pressure Pm	0.42	
Atmospheric Pressure Patm	0.21	
Dry Molecular Weight Md	0.42	
Moisture Content Bws (Absolute)	1.1	
Differential Pressure Head △P	10.0	
Orifice Pressure Differential △H	5.0	
Pitot Tube Coefficient Cp	2.4	
Orifice Meter Coefficient Km	1.5	
Diameter of Probe Nozzle Dn	0.80	

3.3.1 <u>Manual Methods:</u> QA procedures outlined in the test methods were followed, including equipment specifications and operation, calibrations, sample recovery and handling, calculations and performance tolerances.

On-site quality control procedures include pre- and post-test leak checks on trains and pitot systems. If pre-test checks indicate problems, the system is fixed and rechecked before starting testing. If post-test leak checks are not acceptable, the test run is voided and the run is repeated. The results of the quantifiable QA checks for the test runs are on the Field Data sheets.

Horizon does semi-annual calibrations on pitots, thermocouples, and nozzles. Pitots are examined before and after each use to confirm that they are still aligned. Pitot systems are leak-checked before traverses begin, and after runs are completed (before any component disassembly). The results were within allowable tolerances. Prior to use, thermocouple systems are checked for ambient temperature before heaters are started or readings are taken. Problems with connections or polarity are obvious from these and readings as temperatures rise.

3.3.2 <u>Continuous Analyzer Gas Sampling:</u> Analyzer system checks performed are noted on the Calibration Field Record sheet, with procedures documented in the QA/QC section in the Appendix. All calibration standards used in the testing were EPA Protocol 1. Certificates for the gases are in the Appendix.

4. SOURCE DESCRIPTION AND OPERATION

4.1 Process and Control Device Description and Operation:

The wood fired boiler was manufactured by Nebraska, Model S-B00 and is rated at 60,000 pounds of steam per hour. The boiler is used to produce steam for heating the campus during cold weather and to provide steam to absorption chillers to cool the campus buildings in summer. During the testing the boiler steam production averaged 55,700 pounds per hour.

A multiclone controls particulate emissions.

Average Boiler Fuel Sample Information

Wood used during the test was brought to the site in two separate trucks.

One representative sample per truckload was collected.

Primary Fuel:

Hogged Fuel

Wood (estimated): White: 80%

Bark: 20%

Average Moisture, % Wet Basis: 37% Average Percent Dry Fuel <1/8": 7%

4.2 Test Ports: Ports and traverse points are described and diagrammed on the Field Data sheets.

4.2.1 Test Duct Characteristics:

Construction: Steel

Shape: Circular

Size: 58.75 inches inside diameter

Orientation: Vertical

Flow straighteners: None

Extension: None

Cyclonic Flow: None expected Meets EPA M-1 Criteria: Yes

4.3 Process & Control Equipment Flow Diagram: See

Process/Sampling Equipment Flow Diagram in Appendix

4.4 Operating Parameters: See Production/Process Data section of Appendix

4.5 Process Startups/Shutdowns or Other Operational Changes

During Tests: Process was continuous during testing.

5. SAMPLING AND ANALYTICAL PROCEDURES

5.1 Sampling Procedures:

5.1.1 <u>Sampling and Analytical Methods</u>: Testing was conducted in accordance with EPA Methods in <u>Title 40 Code of Federal Regulations</u> Part 60 (40 CFR 60), Appendix A, July 1, 2002.

Flow Rate: EPA Methods 1 and 2 (S-type pitot w/particulate traverses)

CO₂ and O₂: EPA Method 3A (integrated Tedlar bag sample, NDIR and

paramagnetic analyzers)

Moisture: EPA Method 4 (incorporated w/ M-5)

Particulate: EPA Method 5 (filterable material only)

Opacity: EPA Method 9 (thirteen minutes per test)

5.1.2 <u>Sampling Notes:</u> To obtain the fuel moisture content, the wood fuel samples were placed in an oven set at approximately 220°F. The samples are normally dried for 24 hours, however the samples were left in the oven for four days. The entire wood sample obtained during the testing was dried, so it was not possible to repeat the test. The average moisture was 37%, very similar to the plant's measurement of moisture (average 39%) for both truckloads. These results are for information about the fuel used in the boiler, and are not used in any other calculation.

5.1.3 <u>Laboratory Analysis:</u>

Analyte

Laboratory

Particulate

Antech

5.2 Sampling Train Diagrams:

Figure 1
EPA Methods 1, 2, 4, & 5 Particulate Sample Train Diagram




Figure 5-1. Particulate Sampling Train

5.3 Horizon Test Equipment:

5.3.1 Manual Methods:

Equipment Name	<u>Identification</u>
Meter Box	Graseby Model 2010A, Horizon No. 7
Inclined Liquid Manometer	Incorporated with H.E. No. 7
Probe Liner	Stainless Steel
Pitots and Thermocouples	5-2, 5-5, 5-6
Stainless Steel Nozzles	607, 611, 621
Barometer	Test Van III

5.3.2 Continuous Emissions Monitors and Methods:

Gas	Brand	Model	Range	Measurement Method Method	
O_2	Servomex	1400	0-25%	Paramagnetic	3A
CO_2	Servomex	1400	0-25%	Chopperless NDIR	3A

5.3.3 Tedlar Bag Sampling Setup:

Probe:

Stainless Steel

Pump:

Squeeze bulb

6. DISCUSSION

The results of the testing should be valid in all respects. All quality assurance checks including leak checks, instrument checks, and calibrations, were within method-allowable tolerances.